

IBP Fraunhofer Institute for Structural Physics
Stuttgart, 09.06.2016
Test report No. P5-157/2016
Heat Transition Coefficient



tested, DIN EN ISO 12567-1:2010-12 (heater box process)

Wellhöfer Attic Stairs

(Type with additional feature thermal protection WS4D)

Heat Transition Coefficient = 0.58

U-value; W/(m²K)

- > **Component tested insulation value**
for complete attic stairs
- > **Significantly better** than the requirements
of EnEV with regard windows
(German Energy Saving Ordinance; $U \leq 1.3$)